

Отчет о суточных параметрах
(07.11.2021 - 06.12.2021)

Объект: Пермь г, Тимирязева ул, д. 54
Прибор: ИМ2300 А-Е Заводской номер: АВ642
Точка измерения: Узел 1 (истек срок поверки)
У-Ресурс: ТС
Схема измерений: Теплосчетчик с ЧД расхода для ИТП

Дата	T1 °C	T2 °C	T3 °C	T4 °C	T5 °C	dt °C	Gm1 т	Gm2 т	P1 МПа	P2 МПа	Qt1 Гкал	Qt2 Гкал	dQt Гкал	tm1 ч	ts1 ч
07.11.2021	71.62	42.88	70.53	46.74	60.35	28.74	70.47	69.19	0.39	0.26	2.022	1.675	0.348	24.0	24.0
08.11.2021	71.81	42.40	70.70	46.91	60.55	29.41	70.28	68.93	0.39	0.26	2.063	1.670	0.393	24.0	24.0
09.11.2021	71.90	40.36	68.49	44.42	58.09	31.54	60.37	59.15	0.40	0.26	1.837	1.444	0.393	24.0	24.0
10.11.2021	71.36	35.04	65.90	38.94	52.91	36.32	42.25	41.27	0.41	0.26	1.561	1.136	0.425	22.4	24.0
11.11.2021	78.45	33.91	71.86	38.52	55.46	44.54	36.69	35.82	0.40	0.26	1.645	1.197	0.449	24.0	24.0
12.11.2021	81.96	39.56	77.09	43.72	61.85	42.40	52.64	51.56	0.40	0.26	2.175	1.677	0.499	24.0	24.0
13.11.2021	77.00	43.27	73.28	46.93	62.96	33.73	66.53	65.19	0.40	0.27	2.245	1.745	0.499	24.0	24.0
14.11.2021	76.78	43.40	73.00	47.08	62.93	33.37	67.07	65.76	0.40	0.27	2.240	1.731	0.509	24.0	24.0
15.11.2021	84.52	45.72	80.72	49.93	68.03	38.80	64.93	63.68	0.39	0.26	2.522	1.992	0.530	24.0	24.0
16.11.2021	90.60	48.14	87.33	52.67	72.61	42.46	64.23	62.97	0.39	0.26	2.732	2.219	0.512	24.0	24.0
17.11.2021	87.51	47.78	84.46	51.57	70.72	39.73	64.45	63.13	0.40	0.26	2.562	2.113	0.449	24.0	24.0
18.11.2021	87.83	47.75	84.70	51.67	70.93	40.08	65.01	63.70	0.40	0.26	2.607	2.139	0.468	24.0	24.0
19.11.2021	94.72	50.01	91.72	54.43	75.74	44.70	65.03	63.73	0.40	0.26	2.913	2.421	0.492	24.0	24.0
20.11.2021	87.51	46.73	84.00	50.89	70.13	40.77	60.14	58.81	0.37	0.25	2.443	1.995	0.448	24.0	24.0
21.11.2021	79.34	44.64	76.00	48.33	65.08	34.69	65.54	64.25	0.40	0.27	2.274	1.805	0.469	24.0	24.0
22.11.2021	78.41	44.12	74.84	48.06	64.42	34.29	66.77	65.47	0.40	0.26	2.293	1.779	0.514	24.0	24.0
23.11.2021	80.85	45.90	77.70	49.52	66.58	34.94	67.14	65.81	0.40	0.26	2.349	1.884	0.465	24.0	24.0
24.11.2021	84.50	47.42	81.49	51.26	69.32	37.09	67.59	66.25	0.41	0.27	2.509	2.038	0.472	24.0	24.0
25.11.2021	89.34	48.99	86.61	52.98	72.62	40.36	66.66	65.34	0.41	0.27	2.694	2.239	0.455	24.0	24.0
26.11.2021	94.45	50.88	91.80	55.23	76.32	43.57	66.37	64.96	0.40	0.26	2.897	2.421	0.475	24.0	24.0
27.11.2021	86.51	48.83	83.77	52.49	71.12	37.69	68.30	66.76	0.41	0.26	2.574	2.129	0.445	24.0	24.0
28.11.2021	77.81	44.96	74.42	48.71	64.69	32.85	69.17	67.63	0.40	0.26	2.273	1.773	0.500	24.0	24.0
29.11.2021	77.57	43.90	73.98	47.81	63.92	33.67	67.44	65.96	0.40	0.26	2.270	1.758	0.512	24.0	24.0
30.11.2021	75.99	43.62	72.55	47.30	62.97	32.37	67.49	66.07	0.40	0.26	2.185	1.697	0.488	24.0	24.0
01.12.2021	73.14	42.63	69.64	46.29	61.08	30.51	68.17	66.91	0.40	0.26	2.079	1.586	0.494	24.0	24.0
02.12.2021	73.13	43.20	69.80	46.72	61.42	29.93	69.44	68.28	0.41	0.26	2.079	1.596	0.483	24.0	24.0
03.12.2021	74.47	44.18	71.41	47.49	62.60	30.29	69.30	68.20	0.41	0.27	2.099	1.652	0.447	24.0	24.0
04.12.2021	80.35	46.05	77.24	49.69	66.55	34.30	68.83	67.78	0.41	0.26	2.363	1.889	0.474	24.0	24.0
05.12.2021	76.54	45.97	73.71	49.09	64.64	30.57	72.75	71.60	0.44	0.27	2.221	1.778	0.443	24.0	24.0
06.12.2021	82.01	46.59	78.32	50.96	67.85	35.42	72.08	70.99	0.43	0.26	2.555	1.964	0.590	24.0	24.0
Средние:	80.60	44.63	77.24	48.55	65.48	35.97	---	---	0.40	0.26	---	---	---	---	---
Итого:	---	---	---	---	---	---	1943.13	1905.13	---	---	69.281	55.144	14.137	718.4	720.0

Дата	M1	M2	Q1	Q2	Qtv	TWork	QntHIP
	т	т	Гкал	Гкал	Гкал	ч	ч
06.11.2021	90068.77	94895.61	3483.574	2391.383	1092.191	52140.6	54559.7
06.12.2021	92011.90	96800.74	3552.855	2446.527	1106.329	52859.0	55279.7
Итого:	1943.13	1905.13	69.281	55.144	14.137	718.4	720.0

Представитель абонента

Представитель энергоснабжающей организации